Administrative Record

FORT WINGATE DEPOT ACTIVITY, GALLUP, NEW MEXICO

Document No. 95-4

State of New Mexico Environment Department, Review of On-Site Investigation at the Fort Wingate Depot Activity Administration Area, Gallup, New Mexico, (Ground Water Monitoring Requirement Letter, Building 6 UST Area)

Mr. Bill Skinner, New Mexico Environment Department, Underground Storage Tank Bureau

April 1995



Inquiries regarding this Document and/or the Administrative Record for Fort Wingate Depot Activity should be made to: Commander, Tooele Army Depot, Tooele, Utah 84074



State of New Mexico ENVIRONMENT DEPARTMENT Underground Storage Tank Bureau

Harold Runnels Building Harold Runnels Building 1190 St. Francis Drive, P.O. Box 26110 Santa Fe, New Mexico 87502 (505) 827-0188 (505) 827-0310 Fax

MARK E. WEIDLER SECRETARY

EDGAR T. THORNTON, III DEPUTY SECRETARY

GARY E. JOHNSON GOVERNOR

April 18, 1995

Mr. Gary L. Gamel, P.E. Chief, Engineering and Planning Division Department of the Army Albuquerque, New Mexico 87103-1580

RE: REVIEW OF ON-SITE INVESTIGATION AT THE FT. WINGATE DEPOT ACTIVITY ADMINISTRATION AREA, GALLUP, NEW MEXICO

Dear Mr. Gamel:

On April 13, 1995 the New Mexico Environment Department sent a letter requesting a hydrogeologic investigation at the abovereferenced site. Since that time the Department has reviewed the latest water sampling lab results. These results indicate that all water contamination is below state action levels. Therefore, the Department retracts it's request for a hydrogeologic investigation.

The Department is, however, requiring two years of continuous quarterly sampling of the impacted aquifer starting next quarter. These samples should be taken in all monitoring wells on this site when water is present and analysed by EPA Method 8310. The Department requires that a workplan for this monitoring be submitted to the Department for approval as soon as possible.

You may call me at 827-0213 if you have questions.

Sincerely,

Bill Skinner Water Resource Specialist Underground Storage Tank Bureau

cc: Susan Gant, US Army Corps of Engineers NMED District I